

Lighting Tables for New Equipment
3/9/2016

Exit Signs, Occupancy Sensors, and Photocells

DESCRIPTION	WATTS	RETROFIT		NEW CONSTRUCTION	
		CODE	REBATE PER UNIT	CODE	REBATE PER UNIT
Exit Sign – LED (incandescent existing)	2	3007	12.00	---	---
Exit Sign – LED (CFL existing)	2	3008	6.00	---	---
Exit Sign – LEC/Electroluminescent (incandescent existing)	0.3	3009	15.00	---	---
Exit Sign – LEC/Electroluminescent (CFL existing)	0.3	3010	10.00	---	---
Exit Sign – Photoluminescent (incandescent existing)	0	3005	16.00	---	---
Exit Sign – Photoluminescent (CFL existing)	0	3006	11.00	---	---
Wall Mount Occupancy Sensor	---	4001	12.00	4000	6.00
Ceiling Mount Occupancy Sensor	---	4003	36.00	4002	18.00
LED or Fluorescent Lamp or Fixture \geq 25W with Integrated Occupancy Sensor	---	4021	5.00	4020	5.00
LED or Fluorescent Lamp or Fixture \geq 50W with Integrated Occupancy Sensor	---	4023	10.00	4022	10.00
LED or Fluorescent Lamp or Fixture \geq 100W with Integrated Occupancy Sensor	---	4025	15.00	4024	15.00
Photocells	---	4005	12.00	4004	6.00

Definitions:

CFL – Compact Fluorescent Lamp	HO – High Output	LED – Light Emitting Diode	VHO – Very High Output
HBF – High Ballast Factor	HPS – High Pressure Sodium	MH – Metal Halide	
HID – High Intensity Discharge	LEC – Light Emitting Capacitor	RLO – Reduced Light Output	

Integrated Occupancy Sensor – Sensor is permanently integrated into the lamp or fixture by the manufacturer.